



To: CAN Energy Traders, CAN NZ Participants

Date: 19 Sep 2007, 13:32

From: System Operator

**CAN for Grid Asset status change HVDC Pole 1 from
19-Sep-2007 22:00 to 31-Dec-2010 23:59**

"The Grid Owner advises that due to the risk of converter transformer failure due to the ongoing high level of mercury valve arc backs in south transfer, HVDC transfer on pole 1 for southwards flow will cease to be offered from 22.00 hours today. It is not expected that pole 1 will be re-offered for southwards transfer . "

A revision of this notice will be issued if there is any change to the situation advised above.

\\nifs1\schn\reports\CAN\20070919_043929.pdf

LIMITATION OF LIABILITY/DISCLAIMER OF WARRANTY

Transpower make no representation or warranties with respect to the accuracy or completeness of the information contained in this CAN. Unless it is not lawfully permitted to do so, Transpower specifically disclaims any implied warranties of merchantability or fitness for any particular purpose and shall in no event be liable for, any loss of profit or any other commercial damage including but not limited to special, incidental, consequential or other damages.